

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Arthur Peake Centre	Static	CLASSROOM 1006	0.0022	No	
Arthur Peake Centre	With Flush	CLASSROOM 1006	0.0013	No	
Arthur Peake Centre	Static	STAFF 1019	0.00098	No	
Arthur Peake Centre	With Flush	STAFF 1019	0.00094	No	
Arthur Peake Centre	Static	SHOP	0.0026	No	
Arthur Peake Centre	With Flush	SHOP	0.00065	No	
Arthur Peake Centre	Static	CLASSROOM 1003	0.002	No	
Arthur Peake Centre	With Flush	CLASSROOM 1003	0.0011	No	
Arthur Peake Centre	Static	KITCHEN 1018	0.013	Yes	2-minute flush
Arthur Peake Centre	With Flush	KITCHEN 1018	0.0012	No	
Garibaldi Secondary	Static	STAFF 2031	0.0028	No	
Garibaldi Secondary	With Flush	STAFF 2031	0.0026	No	
Garibaldi Secondary	Static	TUBEFEED 2022A	0.0021	No	
Garibaldi Secondary	With Flush	TUBEFEED 2022A	0.00029	No	
Garibaldi Secondary	Static	2028C	0.0042	No	
Garibaldi Secondary	With Flush	2028C	0.00028	No	
Garibaldi Secondary	Static	2042	0.0012	No	
Garibaldi Secondary	Static	STAFF 2206	0.0033	No	
Garibaldi Secondary	With Flush	STAFF 2206	0.00022	No	
Garibaldi Secondary	Static	2227	0.002	No	
Garibaldi Secondary	With Flush	2227	0.00028	No	
Garibaldi Secondary	Static	O/S 2223	0.00053	No	
Garibaldi Secondary	With Flush	O/S 2223	0.00014	No	
Garibaldi Secondary	Static	FOOD 2056-1	0.0007	No	
Garibaldi Secondary	With Flush	FOOD 2056-1	0.00016	No	
Garibaldi Secondary	Static	FOOD 2056-2	0.00072	No	
Garibaldi Secondary	With Flush	FOOD 2056-2	0.00023	No	
Garibaldi Secondary	Static	FOOD 2056-3	0.0038	No	
Garibaldi Secondary	With Flush	FOOD 2056-3	0.00022	No	
Garibaldi Secondary	Static	FOOD 2056-4	0.0011	No	
Garibaldi Secondary	With Flush	FOOD 2056-4	0.00035	No	
Garibaldi Secondary	Static	FOOD 2056-5	0.0019	No	
Garibaldi Secondary	With Flush	FOOD 2056-5	0.00014	No	
Garibaldi Secondary	Static	FOOD 2056-6	0.00086	No	
Garibaldi Secondary	With Flush	FOOD 2056-6	0.00015	No	
Garibaldi Secondary	Static	CAFÉ 2051-1	0.0012	No	
Garibaldi Secondary	With Flush	CAFÉ 2051-1	0.00024	No	
Garibaldi Secondary	Static	2042	0.0077	Yes	2-minute flush
Garibaldi Secondary	With Flush	2042	0.0012	No	
Garibaldi Secondary	Static	CAFÉ 2051-2	0.0081	Yes	2-minute flush
Garibaldi Secondary	With Flush	CAFE2051-2	0.0014	No	
Garibaldi Secondary	Static	CAFÉ 2051-3	0.0044	No	
Garibaldi Secondary	With Flush	CAFE2051-3	0.00041	No	
Garibaldi Secondary	Static	CAFÉ 2051-4	0.0012	No	
Garibaldi Secondary	With Flush	CAFÉ 2051-4	0.0013	No	
Garibaldi Secondary	Static	NURSE OFFICE 2205	0.0059	Yes	2-minute flush

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Garibaldi Secondary	With Flush	NURSE OFFICE 2205	0.0021	No	
Garibaldi Secondary	Static	2210	0.0046	No	
Garibaldi Secondary	With Flush	2210	0.00057	No	
Maple Ridge Secondary	Static	O/S 1221	0.0057	Yes	2-minute flush
Maple Ridge Secondary	With Flush	O/S 1221	0.00062	No	
Maple Ridge Secondary	Static	CHANGE RM 1210	0.00086	No	
Maple Ridge Secondary	With Flush	CHANGE RM 1210	0.0079	Yes	2-minute flush
Maple Ridge Secondary	Static	O/S 1036	0.00018	No	
Maple Ridge Secondary	With Flush	O/S 1036	0.00024	No	
Maple Ridge Secondary	Static	CLASSROOM 122	0.00021	No	
Maple Ridge Secondary	With Flush	CLASSROOM 122	0.0017	No	
Maple Ridge Secondary	Static	1220	0.0027	No	
Maple Ridge Secondary	With Flush	1220	0.0011	No	
Maple Ridge Secondary	Static	O/S 2113	0.00013	No	
Maple Ridge Secondary	With Flush	O/S 2113	0.00009	No	
Maple Ridge Secondary	Static	O/S 2017	0.0016	No	
Maple Ridge Secondary	With Flush	O/S 2017	0.00031	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-1	0.00036	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-1	0.00031	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-2	0.00048	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-2	0.00012	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-3	0.00082	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-3	0.00039	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-4	0.00079	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-4	0.00041	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-5	0.00066	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-5	0.00043	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-6	0.00047	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-6	0.00036	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-7	0.00047	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-7	0.00036	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-1	0.00053	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-1	0.00024	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-2	0.00054	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-2	0.00021	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-3	0.00068	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-3	0.00023	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-4	0.0041	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-4	0.00043	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-5	0.00062	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-5	0.00026	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-6	0.00026	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-6	0.00044	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-7	0.00046	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-7	0.00035	No	
Maple Ridge Secondary	Static	TEACH KIT 1037-1	0.00016	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Maple Ridge Secondary	With Flush	TEACH KIT 1037-1	0.0004	No	
Maple Ridge Secondary	Static	TEACH KIT 1037-2	0.00032	No	
Maple Ridge Secondary	With Flush	TEACH KIT 1037-2	0.00074	No	
Maple Ridge Secondary	Static	TEACH KIT 1037-3	0.00032	No	
Maple Ridge Secondary	With Flush	TEACH KIT 1037-3	0.00021	No	
Maple Ridge Secondary	Static	STAFF 1046	0.00072	No	
Maple Ridge Secondary	With Flush	STAFF 1046	0.00032	No	
Maple Ridge Secondary	Static	KITCHEN 1037	0.00081	No	
Maple Ridge Secondary	With Flush	KITCHEN 1037	0.00068	No	
Maple Ridge Secondary	With Flush	KITCHEN	0.00046	No	
Maple Ridge Secondary	Static	1203	0.00028	No	
Maple Ridge Secondary	With Flush	1203	0.00034	No	
Maple Ridge Secondary	Static	OUTREACH 1230	0.00065	No	
Maple Ridge Secondary	With Flush	OUTREACH 1230	0.00048	No	
Maple Ridge Secondary	Static	1022	0.00037	No	
Maple Ridge Secondary	With Flush	1022	0.00064	No	
Maple Ridge Secondary	Static	SCHOOL OFFICE 1002	0.001	No	
Maple Ridge Secondary	With Flush	SCHOOL OFFICE 1002	0.00037	No	
Maple Ridge Secondary	Static	1005 BATHROOM FAUCET	0.00016	No	
Maple Ridge Secondary	With Flush	1005 BATHROOM FAUCET	0.00048	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-1	0.0015	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-1	0.002	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-2	0.002	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-2	0.00082	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-3	0.0039	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-3	0.0012	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-4	0.0011	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-4	0.00054	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-5	0.00058	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-5	0.00047	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-6	0.0045	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-6	0.00042	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-7	0.00061	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-7	0.00044	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-1	0.00063	No	
Pitt Meadows Secondary	With Flush	KITCHEN1028-1	0.00041	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-2	0.0021	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-2	0.00035	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-3	0.00062	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-3	0.00033	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-4	0.00082	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-4	0.00036	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-5	0.00043	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-5	0.00031	No	
Pitt Meadows Secondary	Static	KITCHEN 1028-6	0.00096	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-6	0.00029	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Pitt Meadows Secondary	Static	KITCHEN 1028-7	0.0011	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028-7	0.0005	No	
Pitt Meadows Secondary	Static	SUPPORT ROOM 1015A	0.0028	No	
Pitt Meadows Secondary	With Flush	SUPPORT ROOM 1015A	0.00047	No	
Pitt Meadows Secondary	Static	KITCHEN 1026	0.011	Yes	2-minute flush
Pitt Meadows Secondary	With Flush	KITCHEN 1026	0.0011	No	
Pitt Meadows Secondary	Static	O/S1010	0.00011	No	
Pitt Meadows Secondary	With Flush	O/S1010	0.00013	No	
Pitt Meadows Secondary	Static	NURSE ROOM 1023	0.00011	No	
Pitt Meadows Secondary	With Flush	NURSE ROOM 1023	0.00031	No	
Pitt Meadows Secondary	Static	O/S 1063	0.0029	No	
Pitt Meadows Secondary	With Flush	O/S 1063	0.0021	No	
Pitt Meadows Secondary	Static	O/S GYM 1054	0.00026	No	
Pitt Meadows Secondary	With Flush	O/S GYM 1054	0.00025	No	
Pitt Meadows Secondary	Static	LIBRARY 2004	0.0012	No	
Pitt Meadows Secondary	With Flush	LIBRARY 2004	0.00075	No	
Pitt Meadows Secondary	Static	YCW 2004B	0.0017	No	
Pitt Meadows Secondary	With Flush	YCW 2004B	0.0003	No	
Pitt Meadows Secondary	Static	O/S 20112A	0.0047	No	
Pitt Meadows Secondary	With Flush	O/S 20112A	0.0009	No	
Pitt Meadows Secondary	Static	CLASSROOM 2222-1	0.0013	No	
Pitt Meadows Secondary	With Flush	CLASSROOM 2222-1	0.0016	No	
Pitt Meadows Secondary	Static	CLASSROOM 2222-2	0.0022	No	
Pitt Meadows Secondary	With Flush	CLASSROOM 2222-2	0.00062	No	
Pitt Meadows Secondary	Static	KITCHEN 1028	0.00082	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028	0.00036	No	
Pitt Meadows Secondary	Static	KITCHEN 1028A	0.0012	No	
Pitt Meadows Secondary	With Flush	KITCHEN 1028A	0.00042	No	
Pitt Meadows Secondary	Static	STAFF 1010	0.003	No	
Pitt Meadows Secondary	With Flush	SEAFF 1010	0.0099	No	
Pitt Meadows Secondary	Static	O/S GYM 1054	0.005	No	
Pitt Meadows Secondary	With Flush	O/S GYM 1054	0.0017	No	
Riverside Centre	Static	1031	0.077	Yes	2-minute flush
Riverside Centre	With Flush	1031	0.0036	No	
Riverside Centre	Static	1030	0.00078	No	
Riverside Centre	With Flush	1030	0.00028	No	
Riverside Centre	Static	STAFF 1034	0.00069	No	
Riverside Centre	With Flush	STAFF 1034	0.00025	No	
Riverside Centre	Static	O/S 1023	0.00037	No	
Riverside Centre	With Flush	O/S 1023	0.00036	No	
Riverside Centre	Static	STAFF 1005	0.0024	No	
Riverside Centre	With Flush	STAFF 1005	0.00069	No	
Riverside Centre	Static	STAFF 1077	0.005	No	
Riverside Centre	With Flush	STAFF 1077	0.005	No	
Riverside Centre	Static	1052	0.021	Yes	2-minute flush
Riverside Centre	With Flush	1052	0.0036	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDICATION
Riverside Centre	Static	1078	0.005	Yes	2-minute flush
Riverside Centre	With Flush	1078	0.00026	No	
Samuel Robertson Technical Secondary	Static	HALLWAY 1285 BF/DF	0.0001	No	
Samuel Robertson Technical Secondary	With Flush	HALLWAY 1285 BF/DF	0	No	
Samuel Robertson Technical Secondary	Static	FOOD 1285-1	0.0011	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1285-1	0.00017	No	
Samuel Robertson Technical Secondary	Static	FOOD 1285-2	0.00087	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1285-2	0.00013	No	
Samuel Robertson Technical Secondary	Static	FOOD 1285-3	0.0018	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1285-3	0.00013	No	
Samuel Robertson Technical Secondary	Static	FOOD 1285-4	0.00069	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1285-4	0.00015	No	
Samuel Robertson Technical Secondary	Static	FOOD 1285-5	0.00093	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1285-5	0.00016	No	
Samuel Robertson Technical Secondary	Static	FOOD 1275-1	0.00071	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1275-1	0.00052	No	
Samuel Robertson Technical Secondary	Static	FOOD 1275-2	0.0011	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1275-2	0.0002	No	
Samuel Robertson Technical Secondary	Static	FOOD 1275-3	0.0029	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1275-3	0.00014	No	
Samuel Robertson Technical Secondary	Static	FOOD 1275-4	0.00076	No	
Samuel Robertson Technical Secondary	With Flush	FOOD 1275-4	0.00016	No	
Samuel Robertson Technical Secondary	Static	1205	0.0054	Yes	2-minute flush
Samuel Robertson Technical Secondary	With Flush	1205	0.003	No	
Samuel Robertson Technical Secondary	Static	LIBRARY 1470	0.0019	No	
Samuel Robertson Technical Secondary	With Flush	LIBRARY 1470	0.00018	No	
Samuel Robertson Technical Secondary	Static	NURSE 1065	0.0013	No	
Samuel Robertson Technical Secondary	With Flush	NURSE 1065	0.00018	No	
Samuel Robertson Technical Secondary	Static	STAFF 1080	0.0084	Yes	2-minute flush
Samuel Robertson Technical Secondary	With Flush	STAFF 1080	0.0012	No	
Samuel Robertson Technical Secondary	Static	2056	0.00009	No	
Samuel Robertson Technical Secondary	With Flush	2065	0.00008	No	
Thomas Haney Secondary	Static	SCIENCE HALL 1145	0.019	Yes	2-minute flush
Thomas Haney Secondary	With Flush	SCIENCE HALL 1145	0.00064	No	
Thomas Haney Secondary	Static	O/S gym 1030	0.00086	No	
Thomas Haney Secondary	With Flush	O/S gym 1030	0.00095	No	
Thomas Haney Secondary	Static	LIBRARY 2018	0.00017	No	
Thomas Haney Secondary	With Flush	LIBRARY 2018	0.00018	No	
Thomas Haney Secondary	Static	ART ROOM 1047	0.001	No	
Thomas Haney Secondary	With Flush	ART ROOM 1047	0.0015	No	
Thomas Haney Secondary	Static	SUPPORT ROOM 2111	0.0021	No	
Thomas Haney Secondary	With Flush	SUPPORT ROOM 2111	0.00018	No	
Thomas Haney Secondary	Static	TEACHER PREP 2111	0.027	Yes	2-minute flush
Thomas Haney Secondary	With Flush	TEACHER PREP 2111	0.002	No	
Thomas Haney Secondary	Static	TEACHER PREP 1155	0.027	No	
Thomas Haney Secondary	With Flush	TEACHER PREP 1156	0.002	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Thomas Haney Secondary	Static	THUNDR CAFÉ 1029	0.0042	No	
Thomas Haney Secondary	With Flush	THUNDR CAFÉ 1029	0.00042	No	
Thomas Haney Secondary	Static	2101	0.0003	No	
Thomas Haney Secondary	With Flush	2101	0.0006	No	
Thomas Haney Secondary	Static	2122	0.0002	No	
Thomas Haney Secondary	With Flush	2122	0.0009	No	
Thomas Haney Secondary	Static	2122-1	0.00093	No	
Thomas Haney Secondary	With Flush	2122-1	0.00014	No	
Thomas Haney Secondary	Static	2122-2	0.00085	No	
Thomas Haney Secondary	With Flush	2122-2	0.00013	No	
Thomas Haney Secondary	Static	2122-3	0.0011	No	
Thomas Haney Secondary	With Flush	2122-3	0.00017	No	
Thomas Haney Secondary	Static	2122-4	0.0023	No	
Thomas Haney Secondary	With Flush	2122-4	0.00068	No	
Thomas Haney Secondary	Static	2122-5	0.0034	No	
Thomas Haney Secondary	With Flush	2122-5	0.00021	No	
Thomas Haney Secondary	Static	2122-6	0.0033	No	
Thomas Haney Secondary	With Flush	2122-6	0.0002	No	
Thomas Haney Secondary	Static	2122-7	0.00068	No	
Thomas Haney Secondary	With Flush	2122-7	0.00018	No	
Thomas Haney Secondary	Static	KITCHEN 1101-1	0.0095	Yes	2-minute flush
Thomas Haney Secondary	With Flush	KITCHEN 1101-1	0.00034	No	
Thomas Haney Secondary	Static	KITCHEN 1101-2	0.0016	No	
Thomas Haney Secondary	With Flush	KITCHEN 1101-2	0.00009	No	
Thomas Haney Secondary	Static	KITCHEN 1101-3	0.003	No	
Thomas Haney Secondary	With Flush	KITCHEN 1101-3	0.0008	No	
Thomas Haney Secondary	Static	KITCHEN 1101-4	0.00089	No	
Thomas Haney Secondary	With Flush	KITCHEN 1101-4	0.0001	No	
Westview Secondary	Static	CAFÉ 1120-A	0.0035	No	
Westview Secondary	With Flush	CAFÉ 1120-A	0.00012	No	
Westview Secondary	Static	CAFÉ 1120-B	0.00012	No	
Westview Secondary	With Flush	CAFÉ 1120-B	0.0044	No	
Westview Secondary	Static	FOOD 1077	0.0014	No	
Westview Secondary	With Flush	FOOD 1077	0.00021	No	
Westview Secondary	Static	NURSE ROOM 1014	0.0026	No	
Westview Secondary	With Flush	NURSE ROOM 1014	0.00014	No	
Westview Secondary	Static	STAFF 1151	0.0024	No	
Westview Secondary	With Flush	STAFF 1151	0.00016	No	
Westview Secondary	Static	O/S 1014	0.00008	No	
Westview Secondary	With Flush	O/S 1014	0.00009	No	
Westview Secondary	Static	O/S 1024	0.00007	No	
Westview Secondary	With Flush	O/S 1024	0.0007	No	
Westview Secondary	Static	O/S 2019	0.0007	No	
Westview Secondary	With Flush	O/S 2019	0.0007	No	
Westview Secondary	Static	O/S 1170	0.0001	No	
Westview Secondary	With Flush	O/S 1170	0.00012	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Westview Secondary	Static	O/S 1165	0.0012	No	
Westview Secondary	With Flush	O/S1165	0.00022	No	
Westview Secondary	Static	NURSE ROOM 1044	0.0024	No	
Westview Secondary	With Flush	NURSE ROOM 1044	0.00019	No	
Westview Secondary	Static	O/S 1078	0.00007	No	
Westview Secondary	With Flush	O/S 1078	0.00007	No	
Westview Secondary	Static	WILDCAFE 1103	0.0012	No	
Westview Secondary	With Flush	WILDCAFE 1103	0.000013	No	
Westview Secondary	Static	1050-A	0.0022	No	
Westview Secondary	With Flush	1050-A	0.000019	No	
Westview Secondary	Static	1190-A	0.004	No	
Westview Secondary	With Flush	1190-A	0.0035	No	
Westview Secondary	Static	1190-B	0.0018	No	
Westview Secondary	With Flush	1190-B	0.0027	No	
Westview Secondary	Static	1190-C	0.0041	No	
Westview Secondary	With Flush	1190-C	0.0033	No	
Westview Secondary	Static	CANTEEN 1186	0.00021	No	
Westview Secondary	With Flush	CANTEEN 1186	0.0048	No	
Westview Secondary	Static	FOOD 1077	0.0022	No	
Westview Secondary	With Flush	FOOD 1077	0.00018	No	
Westview Secondary	Static	1014	0.00078	No	
Westview Secondary	With Flush	1014	0.00008	No	
Westview Secondary	Static	FOOD 1156A	0.00018	No	
Westview Secondary	With Flush	FOOD 1156A	0.00016	No	
Westview Secondary	Static	FOOD 1156B	0.0016	No	
Westview Secondary	With Flush	FOOD 1156B	0.0009	No	
Westview Secondary	Static	FOOD 1156C	0.00019	No	
Westview Secondary	With Flush	FOOD 1156C	0.0044	No	
Westview Secondary	Static	FOOD 1156D	0.00055	No	
Westview Secondary	With Flush	FOOD 1156D	0.00012	No	
Westview Secondary	Static	FOOD 1156E	0.00013	No	
Westview Secondary	With Flush	FOOD 1156E	0.00011	No	
Westview Secondary	Static	FOOD 1156F	0.0031	No	
Westview Secondary	With Flush	FOOD 1156F	0.00021	No	
Westview Secondary	Static	FOOD 1156G	0.0029	No	
Westview Secondary	With Flush	FOOD 1156G	0.00012	No	
Westview Secondary	Static	FOOD 1156H	0.0043	No	
Westview Secondary	With Flush	FOOD 1156H	0.00022	No	
Albion Elementary	Static	FOOD 1840	0.00024	No	
Albion Elementary	With Flush	FODD 1840	0.00016	No	
Albion Elementary	Static	1110	0.0062	Yes	2-minute flush
Albion Elementary	With Flush	1110	0.0019	No	
Albion Elementary	Static	SAFF 1330	0.00063	No	
Albion Elementary	With Flush	SAFF 1330	0.00033	No	
Albion Elementary	Static	NURSE 1370	0.0031	No	
Albion Elementary	With Flush	NURSE 1370	0.00045	No	



FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Albion Elementary	Static	1600	0.0022	No	
Albion Elementary	With Flush	1600	0.00019	No	
Albion Elementary	Static	CLASSROOM 1720	0.00014	No	
Albion Elementary	With Flush	CLASSROOM 1720	0.00014	No	
Albion Elementary	Static	CLASSROOM 1800	0.00061	No	
Albion Elementary	With Flush	CLASSROOM 1800	0.00014	No	
Alexander Robinson Elementary	Static	1042	0.0007	No	
Alexander Robinson Elementary	With Flush	1042	0.00062	No	
Alexander Robinson Elementary	Static	FOOD 1043	0.00063	No	
Alexander Robinson Elementary	With Flush	FOOD 1043	0.00054	No	
Alexander Robinson Elementary	Static	STAFF 2002	0.00018	No	
Alexander Robinson Elementary	With Flush	STAFF 2002	0.00024	No	
Alexander Robinson Elementary	Static	STAFF 1006	0.00033	No	
Alexander Robinson Elementary	With Flush	STAFF 1006	0.00026	No	
Alouette Elementary	Static	FOOD 1073	0.0027	No	
Alouette Elementary	With Flush	FOOD 1073	0.00015	No	
Alouette Elementary	Static	GYM 1001	0.003	No	
Alouette Elementary	With Flush	GYM 1001	0.00035	No	
Alouette Elementary	Static	STAFF 1017	0.0012	No	
Alouette Elementary	With Flush	STAFF 1017	0.00015	No	
Alouette Elementary	Static	1031	0.0022	No	
Alouette Elementary	With Flush	1031	0.00067	No	
Alouette Elementary	Static	NURSE 1015	0.0019	No	
Alouette Elementary	With Flush	NURSE 1015	0.00026	No	
Alouette Elementary	Static	DAYCARE	0.00039	No	
Alouette Elementary	With Flush	DAYCARE	0.00016	No	
Blue Mountain Elementary	Static	KITCHEN 1037	0.00059	No	
Blue Mountain Elementary	With Flush	KITCHEN 1037	0.00078	No	
Blue Mountain Elementary	Static	1028	0.00026	No	
Blue Mountain Elementary	With Flush	1028	0.00048	No	
Blue Mountain Elementary	Static	CLASSROOM 1042	0.0053	Yes	2-minute flush
Blue Mountain Elementary	With Flush	CLASSROOM 1042	0.0008	No	
Blue Mountain Elementary	Static	STAFF 1048	0.0012	No	
Blue Mountain Elementary	With Flush	STAFF 1048	0.00043	No	
Blue Mountain Elementary	Static	1010	0.00034	No	
Blue Mountain Elementary	With Flush	1010	0.00034	No	
c'usquanela Elementary	Static	STAFF 129	0.001	No	
c'usquanela Elementary	With Flush	STAFF 129	0.0007	No	
c'usquanela Elementary	Static	SALMON POD#7	0.00022	No	
c'usquanela Elementary	With Flush	SALMON POD#7	0.0009	No	
c'usquanela Elementary	Static	ORCA POD# 3	0.0004	No	
c'usquanela Elementary	With Flush	ORCA POD# 3	0.00008	No	
c'usquanela Elementary	Static	FOOD 107	0.00018	No	
c'usquanela Elementary	With Flush	FOOD 107	0.00008	No	
c'usquanela Elementary	Static	THUNDER POD#9	0.00048	No	
c'usquanela Elementary	With Flush	THUNDER POD#9	0.00007	No	



FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
c'usqunela Elementary	Static	HUMMINBIRD POD #1	0.00014	No	
c'usqunela Elementary	With Flush	HUMMINBIRD POD #1	0.00007	No	
c'usqunela Elementary	Static	O/S GYM 147	0.0007	No	
c'usqunela Elementary	With Flush	O/S GYM 147	0.00007	No	
c'usqunela Elementary	Static	BOBCAT POD CLASS	0.00065	No	
c'usqunela Elementary	With Flush	BOBCAT POD CLASS	0.0007	No	
c'usqunela Elementary	Static	BEAR POD	0.00073	No	
c'usqunela Elementary	With Flush	BEAR POD	0.0001	No	
c'usqunela Elementary	Static	BEAR POD	0.00068	No	
c'usqunela Elementary	With Flush	BEAR POD	0.00011	No	
Davie Jones Elementary	Static	STAFF 1027	0.00036	No	
Davie Jones Elementary	With Flush	STAFF 1027	0.00041	No	
Davie Jones Elementary	Static	STRONG START	0.004	No	
Davie Jones Elementary	With Flush	STRONG START	0.0012	No	
Davie Jones Elementary	Static	1020	0.00028	No	
Davie Jones Elementary	With Flush	1020	0.00033	No	
Davie Jones Elementary	Static	1031	0.00036	No	
Davie Jones Elementary	With Flush	1031	0.0004	No	
Edith McDermott Elementary	Static	2007 KITCHEN	0.00057	No	
Edith McDermott Elementary	With Flush	2007 KITCHEN	0.00059	No	
Edith McDermott Elementary	Static	1036 Kitchen	0.00049	No	
Edith McDermott Elementary	With Flush	1036 Kitchen	0.00054	No	
Edith McDermott Elementary	Static	O/S 1027	0.00046	No	
Edith McDermott Elementary	With Flush	O/S 1027	0.00041	No	
Edith McDermott Elementary	Static	CLASSROOM1019	0.00042	No	
Edith McDermott Elementary	With Flush	CLASSROOM1019	0.00051	No	
Edith McDermott Elementary	Static	NURSE OFFICE 1006	0.00052	No	
Edith McDermott Elementary	With Flush	NURSE OFFICE 1006	0.00056	No	
Edith McDermott Elementary	Static	CLASSROOM 2030	0.00056	No	
Edith McDermott Elementary	With Flush	CLASSROOM 2030	0.00053	No	
Edith McDermott Elementary	Static	CLASSROOM 1023	0.00051	No	
Edith McDermott Elementary	With Flush	CLASSROOM 1023	0.00039	No	
Edith McDermott Elementary	Static	CLASSROOM 2002	0.00054	No	
Eric Langton Elementary	Static	O/S 1034	0.0076	Yes	2-minute flush
Eric Langton Elementary	With Flush	O/S 1034	0.00089	No	
Eric Langton Elementary	Static	FOOD 1036	0.0061	Yes	2-minute flush
Eric Langton Elementary	With Flush	FOOD 1036	0.00028	No	
Eric Langton Elementary	Static	FOOD 1065	0.0035	No	
Eric Langton Elementary	With Flush	FOOD 1056	0.00024	No	
Eric Langton Elementary	Static	FOOD 1003	0.038	Yes	2-minute flush
Eric Langton Elementary	With Flush	FOOD 1003	0.0011	No	
Eric Langton Elementary	Static	NURSE 1028	0.0076	Yes	2-minute flush
Eric Langton Elementary	With Flush	NURSE 1028	0.00035	No	
Eric Langton Elementary	Static	STAFF 1025A	0.00034	No	
Eric Langton Elementary	With Flush	STAFF 1025A	0.00017	No	
Eric Langton Elementary	Static	FOOD 1065 RIGHT	0.0022	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Eric Langton Elementary	With Flush	FOOD 1065 RIGHT	0.00022	No	
Eric Langton Elementary	Static	DAYCARE	0.0041	No	
Eric Langton Elementary	With Flush	DAYCARE	0.00023	No	
Fairview Elementary	Static	CLASSROOM 1023	0.001	No	
Fairview Elementary	With Flush	CLASSROOM 1023	0.00073	No	
Fairview Elementary	Static	CLASSROOM 1024	0.004	No	
Fairview Elementary	With Flush	CLASSROOM 1024	0.00058	No	
Fairview Elementary	Static	FOOD 1037	0.00036	No	
Fairview Elementary	With Flush	FOOD 1037	0.00035	No	
Fairview Elementary	Static	STAFF 1046	0.00036	No	
Fairview Elementary	With Flush	STAFF 1046	0.00042	No	
Fairview Elementary	Static	FOOD 1003	0.0046	No	
Fairview Elementary	With Flush	FOOD 1003	0.00069	No	
Fairview Elementary	Static	O/S WR1012	0.0002	No	
Fairview Elementary	With Flush	O/S WR 1012	0.00023	No	
Fairview Elementary	Static	O/S WR 1001	0.00085	No	
Fairview Elementary	With Flush	O/S WR1001	0.00086	No	
Glenwood Elementary	Static	CLASSROOM 1018	0.005	Yes	2-minute flush
Glenwood Elementary	With Flush	CLASSROOM 1018	0.00044	No	
Glenwood Elementary	Static	STAFF 1025	0.0037	No	
Glenwood Elementary	With Flush	STAFF 1025	0.00044	No	
Glenwood Elementary	Static	MULTI-PRP 1015	0.00041	No	
Glenwood Elementary	With Flush	MULTI-PRP 1015	0.00015	No	
Glenwood Elementary	Static	STAFF 1034	0.0027	No	
Glenwood Elementary	With Flush	STAFF 1034	0.00015	No	
Glenwood Elementary	Static	DAYCARE	0.00015	No	
Glenwood Elementary	With Flush	DAYCARE	0.00013	No	
Golden Ears Elementary	Static	CLASSROOM 1071	0.00061	No	
Golden Ears Elementary	With Flush	CLASSROOM 1071	0.00009	No	
Golden Ears Elementary	Static	CLASSROOM 1027	0.011	Yes	2-minute flush
Golden Ears Elementary	With Flush	CLASSROOM 1027	0.00045	No	
Golden Ears Elementary	Static	CLASSROOM 1078	0.0047	No	
Golden Ears Elementary	With Flush	CLASSROOM 1078	0.00015	No	
Golden Ears Elementary	Static	O/S 1033	0.00011	No	
Golden Ears Elementary	With Flush	O/S 1033	0.0015	No	
Golden Ears Elementary	Static	STAFF	0.0014	No	
Golden Ears Elementary	With Flush	STAFF	0.00012	No	
Golden Ears Elementary	Static	FOOD 1017	0.019	Yes	2-minute flush
Golden Ears Elementary	With Flush	FOOD 1017	0.00061	No	
Golden Ears Elementary	Static	CLASSROOM 1012	0.011	Yes	2-minute flush
Golden Ears Elementary	With Flush	CLASSROOM 1012	0.00022	No	
Golden Ears Elementary	Static	CLASSROOM 1007	0.011	Yes	2-minute flush
Golden Ears Elementary	With Flush	CLASSROOM 1007	0.00048	No	
Golden Ears Elementary	Static	NURSE 1001	0.00059	No	
Golden Ears Elementary	With Flush	NURSE 1001	0.00016	No	
Golden Ears Elementary	Static	FOOD 1017	0.01	Yes	2-minute flush

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Golden Ears Elementary	With Flush	FOOD 1017	0.0004	No	
Hammond Elementary	Static	STAFF 2002	0.0011	No	
Hammond Elementary	With Flush	STAFF 2002	0.00044	No	
Hammond Elementary	Static	CLASSROOM 1019	0.0012	No	
Hammond Elementary	With Flush	CLASSROOM 1019	0.00033	No	
Hammond Elementary	Static	CLASSROOM 1017	0.00068	No	
Hammond Elementary	With Flush	CLASSROOM 1017	0.0004	No	
Hammond Elementary	Static	CLASSROOM 1015	0.00083	No	
Hammond Elementary	With Flush	CLASSROOM 1015	0.0018	No	
Hammond Elementary	Static	CLASSROOM 1015	0.00083	No	
Hammond Elementary	With Flush	CLASSROOM 1015	0.00062	No	
Hammond Elementary	Static	CLASSROOM 1013	0.0018	No	
Hammond Elementary	With Flush	CLASSROOM 1013	0.00058	No	
Hammond Elementary	Static	CLASSROOMN1016	0.0036	No	
Hammond Elementary	With Flush	CLASSROOMN1016	0.0011	No	
Hammond Elementary	Static	CLASSROOM 1006	0.00039	No	
Hammond Elementary	With Flush	CLASSROOM 1006	0.00039	No	
Hammond Elementary	Static	CLASSROOM 1043	0.00021	No	
Hammond Elementary	With Flush	CLASSROOM 1043	0.00054	No	
Harry Hooge Elementary	Static	NURSE 1005	0.00057	No	
Harry Hooge Elementary	With Flush	NURSE 1005	0.00016	No	
Harry Hooge Elementary	Static	CLASSROOM 1024	0.00059	No	
Harry Hooge Elementary	With Flush	CLASSROOM 1024	0.0013	No	
Harry Hooge Elementary	Static	O/S 1071	0.00018	No	
Harry Hooge Elementary	With Flush	O/S 1071	0.00021	No	
Harry Hooge Elementary	Static	FOOD 1056	0.003	No	
Harry Hooge Elementary	With Flush	FOOD 1056	0.00024	No	
Harry Hooge Elementary	Static	NURSE 1041	0.0081	Yes	2-minute flush
Harry Hooge Elementary	With Flush	NURSE 1041	0.00047	No	
Harry Hooge Elementary	Static	1042	0.0011	No	
Harry Hooge Elementary	With Flush	1042	0.00019	No	
Highland Park Elementary	Static	FOOD CW	0.00064	No	
Highland Park Elementary	With Flush	FOOD CW	0.00067	No	
Highland Park Elementary	Static	STAFF 1005C	0.00069	No	
Highland Park Elementary	With Flush	STAFF 1005C	0.00062	No	
Highland Park Elementary	Static	O/S 1012	0.002	No	
Highland Park Elementary	With Flush	O/S 1012	0.0014	No	
Kanaka Creek Elementary	Static	MULTI-PRP 1034	0.005	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	MULTI-PRP 1034	0.0037	No	
Kanaka Creek Elementary	Static	KITCHEN 1031	0.011	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	KITCHEN 1031	0.00038	No	
Kanaka Creek Elementary	Static	CLASSROOM 1021	0.005	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	CLASSROOM 1021	0.00057	No	
Kanaka Creek Elementary	Static	STAFF 1008	0.0018	No	
Kanaka Creek Elementary	With Flush	STAFF 1008	0.00024	No	
Laityview Elementary	Static	O/S 1035	0.00023	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Laityview Elementary	With Flush	O/S 1035	0.00009	No	
Laityview Elementary	Static	STAFF 1028	0.0013	No	
Laityview Elementary	With Flush	STAFF 1028	0.00024	No	
Laityview Elementary	Static	CLASSROOM 1021	0.0019	No	
Laityview Elementary	With Flush	CLASSROOM 1021	0.00018	No	
Laityview Elementary	Static	O/S 1023	0.0055	Yes	2-minute flush
Laityview Elementary	With Flush	O/S 1023	0.00075	No	
Laityview Elementary	Static	ST 1035AFF	0.00039	No	
Laityview Elementary	With Flush	STAFF 1035	0.00009	No	
Laityview Elementary	Static	CLASSROOM 1009	0.0042	No	
Laityview Elementary	With Flush	CLASSROOM 1009	0.0019	No	
Laityview Elementary	Static	NURSE 1029	0.0021	No	
Laityview Elementary	With Flush	NURSE 1029	0.00071	No	
Laityview Elementary	Static	CLASSROOM 1032	0.0058	Yes	2-minute flush
Laityview Elementary	With Flush	CLASSROOM 1032	0.00036	No	
Maintenance Building	Static	STAFF 1018	0.0016	No	
Maintenance Building	With Flush	STAFF 1018	0.0012	No	
Maple Ridge Elementary	Static	FOOD 1037	0.00028	No	
Maple Ridge Elementary	With Flush	FOOD 1037	0.00022	No	
Maple Ridge Elementary	Static	O/S 1019	0.00022	No	
Maple Ridge Elementary	With Flush	O/S 1019	0.00017	No	
Maple Ridge Elementary	Static	STAFF 1007	0.00018	No	
Maple Ridge Elementary	With Flush	STAFF 1007	0.00024	No	
Maple Ridge Elementary	Static	O/S 1010	0.00016	No	
Maple Ridge Elementary	With Flush	O/S1010	0.00018	No	
Maple Ridge Elementary	Static	NURSE 1004	0.00092	No	
Maple Ridge Elementary	With Flush	NURSE 1004	0.00048	No	
Maple Ridge Elementary	Static	O/S 1207	0.00037	No	
Maple Ridge Elementary	With Flush	O/S 1207	0.0002	No	
Maple Ridge Elementary	Static	1208	0.00034	No	
Maple Ridge Elementary	With Flush	1208	0.00018	No	
Pitt Meadows Elementary	Static	STAFF 1003	0.0011	No	
Pitt Meadows Elementary	With Flush	STAFF 1003	0.001	No	
Pitt Meadows Elementary	Static	O/S 1003	0.00063	No	
Pitt Meadows Elementary	With Flush	O/S 1003	0.00063	No	
Pitt Meadows Elementary	Static	O/ST 1050	0.00084	No	
Pitt Meadows Elementary	With Flush	O/S 1050	0.0011	No	
Pitt Meadows Elementary	Static	CLASSROOM 1005A	0.00074	No	
Pitt Meadows Elementary	With Flush	CLASSROOM 1005A	0.0011	No	
Pitt Meadows Elementary	Static	O/S 1027	0.0012	No	
Pitt Meadows Elementary	With Flush	O/S 1027	0.0012	No	
Pitt Meadows Elementary	Static	FOOD 1053	0.0011	No	
Pitt Meadows Elementary	With Flush	FOOD 1053	0.00099	No	
Pitt Meadows Elementary	Static	CLASSROOM 1044	0.0011	No	
Pitt Meadows Elementary	With Flush	CLASSROOM 1044	0.001	No	
Pitt Meadows Elementary	Static	DAYCARE MOO02	0.00096	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Pitt Meadows Elementary	With Flush	DAYCARE MO002	0.00069	No	
Webster's Corners Elementary	Static	FOODS 1138	0.00051	No	
Webster's Corners Elementary	With Flush	FOODS 1138	0.0003	No	
Webster's Corners Elementary	Static	CLASSROOM 1170	0.00047	No	
Webster's Corners Elementary	With Flush	CLASSROOM 1170	0.00064	No	
Webster's Corners Elementary	Static	STAFF 1111	0.00026	No	
Webster's Corners Elementary	With Flush	STAFF 1111	0.00024	No	
Webster's Corners Elementary	Static	HALLWAY 1105	0.0015	No	
Webster's Corners Elementary	With Flush	HALLWAY 1105	0.00038	No	
Webster's Corners Elementary	Static	NURSE 1115	0.011	Yes	2-minute flush
Webster's Corners Elementary	With Flush	NURSE 1115	0.00069	No	
Yennadon Elementary	Static	1019	0.0026	No	
Yennadon Elementary	With Flush	1019	0.001	No	
Yennadon Elementary	Static	1018A	0.0055	Yes	2-minute flush
Yennadon Elementary	With Flush	1018A	0.00032	No	
Yennadon Elementary	Static	CLASSROOM 1135	0.011	Yes	2-minute flush
Yennadon Elementary	With Flush	CLASSROOM 1135	0.00022	No	
Yennadon Elementary	Static	BATHROOM 1109	0.0072	Yes	2-minute flush
Yennadon Elementary	With Flush	BATHROOM 1109	0.00021	No	
Yennadon Elementary	Static	PAC 1038	0.005	No	
Yennadon Elementary	With Flush	PAC 1038	0.00019	No	
Yennadon Elementary	Static	BF 1023	0.00009	No	
Yennadon Elementary	With Flush	BF 1023	0.00006	No	
Yennadon Elementary	Static	FOOD 1088	0.0097	Yes	2-minute flush
Yennadon Elementary	With Flush	1088	0.0005	No	